

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany
Phone +49 621 776-0
Fax +49 621 776-1000

No. / Nr.: DOC-4797
Date / Datum: 2020-08-13

Copyright Pepperl+Fuchs
www.pepperl-fuchs.com

 PEPPERL+FUCHS

Declaration of conformity / Konformitätserklärung

The above mentioned agent declares under sole responsibility that the **products** listed below are in conformity with the listed **European Directives** and **standards**.

Product family / Produktfamilie

| Productfamily / Produktfamilie | ID | Description / Beschreibung |
|--------------------------------|-----------------------------|---|
| Plugs & Sockets | PS16*, PS32*, PS63*, PS125* | Ex de plugs and sockets in GRP enclosures |

The „*“ marked symbol of the type code is a placeholder and can be replaced by the code described on the product name plate.

Directives and Standards / Richtlinien und Normen

| EU-Directive / EU-Richtlinie | Standards / Normen |
|---------------------------------|---|
| 2014/34/EU (ATEX) (L96/309-356) | EN 60079-0: 2012+A11: 2013 EN 60079-1: 2014 EN 60079-7: 2015 EN 60079-31: 2014 |
| 2014/35/EU (LVD) (L96/357-374) | EN 60309-1:2012 EN 60309-2:2012 EN 60309-4:2012 |
| 2011/65/EU (RoHS) (L174/88-110) | EN 50581:2012-09 |


Affixed CE Marking / Angebrachte CE-Kennzeichnung




0102

Signatures / Unterschriften

Mannheim, 2020-08-13


 ppa. Hermann Best
 Vice President EPE
 Products & Solutions


 i.V. Rainer Nägle
 Manager Product Group EPE
 & Solutions

ANNEX 2014/34/EU (ATEX)

Notified Body QM-System / Notifizierte Stelle des QM-Systems:
Physikalisch Technische Bundesanstalt (0102)
Bundesallee 100
38116 Braunschweig
Germany

Certificates issued for the products listed above are based on European standards that are no longer harmonized under the ATEX directive.

Pepperl+Fuchs SE declares that the products are only affected by minor or formal changes with respect to the new edition of the standards. These changes are not relevant for compliance with the essential health and safety requirements. The products still comply with the ATEX Directive. This declaration is also valid if the marking and the certificates of the listed devices correspond to previous editions of standards.

The EC-Type-Examination and the marking of the products was performed in accordance with the following standards:

EN 60079-0: 2009
EN 60079-1: 2007
EN 60079-7: 2007
EN 60079-31: 2007

Marking and Certificates / Kennzeichnung und Zertifikate

| Products / Produkte | Control Stations | |
|---|--------------------------|---------------------------|
| Marking / Kennzeichnung | Certificate / Zertifikat | Issuer ID / Aussteller ID |
|  | SIRA 11ATEX1044 | 0518 |

Legend of issuer / Legende der Aussteller

| ID | Issuer / Aussteller |
|------|---|
| 0518 | Sira Certification Service Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom |